

Complete list 1

VX-XA-X/X_X/XX-X/X

First "X" : denoted Outlet Number and Outlet Type, is Outlet Number may be 1 to 48, Outlet Type is may be "US" or "C13" or "C19" or "UK45" or "UK90" or "UK135" or "SCH" or "FR" or Other, "US" = NEMA, "C13" = IEC C13, "C19" = IEC C19, "UK45" = BS1363 45 degree, "UK90" = BS1363 90 degree, "UK135" = BS1363 135 degree, "SCH" = Schuko, "FR" = France, if multiple composition between Outlet type and Outlet Number is "/";

Second "X" : denoted Total Output Ampere; is may be 0 to 32;

Third "X" : denoted Control or Meter Type, is may be "MD" or "W" or "Wi" or "WS" or "WSi" or Blank, "MD" = Metered PDU, "W" = kWh Monitored PDU, "Wi" = Outlet Level kWh Monitored PDU, "WS" = kWh Switched PDU, "WSi" = Outlet Level kWh Switched PDU, Blank = Basic PDU;

Fourth "X" : denoted Protect Type, is may be "F" or "CR" or "GF" or Other, "F" = Fuse, "CR" = Circuit Breaker, "GF" = Individual Fuse; Blank is not Protect;

Fifth X : denoted Input Plug and Wire Type, is may be "EN" or "C14" or "C20" or "OE" or "BS" or "CEE7" or "L620" or "L630" or "L520" or "L530" or "520" or "530" or "TP" or Other, If there are two input Wires, followed by "/TP", "EN" = EN 60309, "C14" = C14 plug, "C20" = C20 plug, "OE" = Open End, "BS" = BS1363, "CEE7" = CEE7, "L620" = L6-20P, "L630" = L6-30P, "L520" = L5-20P, "L530" = L5-30P, "520" = 5-20P, "530" = 5-30P, "TP" = Twin Power Wire;

Sixth "X" : denoted Cord Length, is may be "1" or "1.5" or "2" or "2.5" or "3" or "3.5" or "4" or "4.5" or "5" or Other, "1" = 1m /3.28 feet;, "1.5" = 1.5m / 4.92 feet, "2" = 2m / 6.56Feet, "2.5" = 2.5m / 8.2 Feet, "3" = 3m / 9.84 Feet, "3.5" = 3.5m /11.48 Feet, "4" = 4m / 13.1 Feet, "4.5" = 4.5m / 14.76 feet, "5" = 5m / 16.4 Feet;

Seventh "X" : denoted place from, is may be "T" or "B" or Other, "T" = Top Feed, "B" = Bottom Feed is only for Vertical;

Eighth "X" : denoted Outlet Case Color, is may be "1" or "2" or "3" or "4" or Other, "1" = Black, "2" = White, "3" = Red, "4" = Blue

Ninth "X" : denoted sensor type or filter type, is may be "T" or "TH" or "EMI" or "SPT" or other.
T = Temperature sensor; TH = Temperature & humidity sensor; EMI = EMI filter;
SPT = Surge protector;